

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-1516:100

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: AES Corporation, 285 Newbury Street, Peabody, MA 01960
Contact: Thomas Kenty (978) 535-7310 Fax (978) 535-7313

DESIGN: Model 7750 Subscriber Unit two way RF transceiver. Unit is intended for use with listee's separately listed Model IntelliNet 7700 system (7300-1516:101) and AMSECO Model XP-1640 Class 2 Plug-in Transformer. The 7750 subscriber unit is an add-on equipment intended to provide radio frequency reporting for fire and burglary alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 16.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as a two-way transceiver unit for use with separately listed compatible fire alarm control units.

- NOTE:**
1. The 7750 unit is required to be mounted within 3 feet of the fire alarm control unit. All interconnecting wiring between the control unit and the 7750 unit shall be in conduit with no intervening walls or barriers between the two units. Authority having jurisdiction should be consulted prior to installation.
 2. The 7750 shall not be used with more than one Zone Expansion Board.
 3. The Rs-232 port connector on the rear circuit of the 7750 is not approved for zone input device.

10-01-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager